

# CE TEST CERTIFICATE

FOR PERFORMANCE CHARACTERISTICS OF CONSTRUCTION PRODUCTS FOR THE CE MARKING

BOD-17-10-25-05

**Product:** Laminate floor coverings  
Pergo laminate class 33  
Thicknesses: 8 – 12 mm

**Producer:** Unilin Flooring BV, Ooigemstraat 3, 8710 Wielsbeke, Belgium

**Order:** Testing and classification of selected properties according to EN 14041:2008 (CE-labelling)

**Test reports:** 2716542/1


**Test results:**

Property	Declaration according to EN 14041:2008
Reaction to fire performance according to EN ISO 9239-1:2010 and EN ISO 11925-2:2011; Classification according to EN 13501-1:2010	Reaction to fire class B <sub>fl</sub> - s1
Anti-sliding properties according to EN 13893:2003	class DS
Formaldehyde emission according to EN 717-1:2004	class E1
Thermal resistance according to EN 12667:2001	≤ 0.10 (m <sup>2</sup> K)/W
Body voltage according to EN 1815:2016	Antistatic Floor Covering

Dresden, 25 October 2017



Head of laboratory

Engineer in charge